

***FRAZIER PARK PUBLIC UTILITY
DISTRICT***

MANAGERS REPORT

For the month of March 2026

Prepared by:

Jonnie Allison, General Manager

Frazier Park Public Utility District

INFORMATIONAL ITEMS

I. WATER REPORT

Water Pumped this month 909,500 Cubic Ft.

Water sold: 536,016 Cubic Ft.

Water used for Fire & Flushing Line: 63,665 Cubic Ft.

Water Loss: 309,819 Cubic Ft.

Lag Differential: 34.07%

II. MAINTENANCE AND REPAIR: March 2026

Description	Current Month	Last Mo.	Calendar Yr to date
METER CHANGES	0	0	0
AFTER HOUR CALL OUTS	0	5	9
MAIN LINE LEAK REPAIRS	2	2	5
USA LOCATES	10	20	36
SERVICE/WORK ORDERS***	191	222	1306
CUSTOMER "TURN-ONS"	0	0	2
CUSTOMER "TURN-OFFS"	1	1	3
LOCK OFF (NON PAYMENT)	7	8	24
SERVICE RECONNECT	7	9	22
SHUT OFF NOTICES	34	37	104
WATER QUALITY COMPLAINTS	0	0	0
WATER OUTAGES	0	0	1
SERVICE LINE BREAKS	0	0	0
BOIL WATER NOTICES	0	0	700

III. WATER QUALITY COMPLAINTS:

IV. ISSUES AND ACTIONS:

There was (2) mainline break(s) / repair(s) in the month of March 2026

Location	Dates	Comments
3420 Kansas Trail and East End	3/2/26	Used 2 6" compression coupling 6.75-7.56 1 3ft section of 6" C-900
3420 Kansas Trail and East End	3/2/26	Used 2 single bolt 2.38, 1 failed

- There was (0) after hour callout(s) in the month of March 2026

Location	Date	Reason

V. NEW SERVICES INSTALLED: (0)

VI. NEW BUSINESS:

- **APPLICATIONS FOR WATER SERVICE - 0**